

**KERALA STATE CO-OPERATIVE BANK LTD,
HEAD OFFICE, CO-BANK TOWERS, PALAYAM
THIRUVANANTHAPURAM**



Quotation Notice

Quotation of Supply/Installation of UPS Set – reg.

Kerala State Co-operative Bank Ltd. inviting Sealed Competitive quotations from experienced Firms/Suppliers/Dealers on behalf of Managing Director, for Supply/Installation of UPS set at Head Office Building of Kerala State Co-operative Bank Ltd.

The last date of receipt of quotations and the specification of UPS and quantity are given below.

- 1 The last date & time of receipt of quotation : 01.11.2017 : 3 PM
- 2 Quotation addressed to : The Managing Director
KSCB Ltd, Co-bank Towers
Vikas Bhavan P O, PMG,
Thiruvananthapuram
695033
- 3 For more details visit Website : www.kerlacobank.com.
- 4 For any further information call : Mobile : 9946951643
Office : 0471-2547228

Sd/-
Assistant Engineer (Electrical)
Kerala State Co-operative Bank Ltd.

23.10.2017
Thiruvananthapuram

Invitation for quotation for supply of 6KVA/3KVA UPS system

1) Schedule of Item

Sl.No.	Description	Quantity
1.	<p>Supply and installation of 6KVA online UPS with following specification. IGBT based PWM Technology online UPS</p> <p>Nominal output Voltage - 230 +1%(single phase) Frequency - 50Hz + 0.1% Wareform - Pure sine wave Input voltage - 170-250 volts Battery Backup required - 120 minutes</p> <p>Should have bypass mode Output of duty - 0.8 lagging to unity continuous THD - 2% less than for linear load - 5% less than for non linear load</p> <p>Battery-10 No's x 100 AH tubular battery (EXIDE / Luminous/Amron/equivalent) <u>Warranty</u> UPS - 1 year (Replacement) + 1 year (service) Battery - 2 year (Replacement) + 2 year (service)</p>	1 set
2.	<p>Supply and installation of 3KVA online UPS with following specification. IGBT based PWM Technology online UPS</p> <p>Nominal output Voltage - 230 ±1%(single phase) Frequency - 50Hz ± 0.1% Wareform - Pure sine wave Input voltage - 170-250 volts Battery Backup required - 120 minutes</p> <p>Should have bypass mode Output pf duty - 0.8 lagging to unity Continuous THD - 2% less than for linear load - 5% less than for non linear load</p> <p>Battery-6 No's x 100 AH tubular battery (EXIDE / Luminous/Amron/equivalent) <u>Warranty</u> UPS - 1 year (Replacement) + 1 year (service) Battery - 2 year (Replacement) + 2 year (service)</p>	1 set

..2..

3.	Disposal of old Batteries/Buy Back	
	a) 80AH Tubular Damaged Batteries	15 No's
	b) 50AH Tubular Damaged Batteries	16 No's

2) Bid Price

- a) The Contractor shall be for the fully quantity as described above. Corrections if any shall be made by crossing out, rewriting with initial and date.
- b) The rate should be all inclusive – taxes levies transport etc.
- c) Usual deduction will be made from the gross amount of bill.
- d) The rate quoted by the bidder shall be fixed for the duration of the contract and shall not be subject to adjustment on any account.
- e) Prices should be quoted in Indian Rupees only.

3) Each bidder shall submit only one quotation

4) Validity of Quotation

Quotation shall remain valid for a period not less than 45 days after the deadline date specified for submission.

5) Evaluation of Quotation

The purchaser will evaluate and compare the quotation determined to be substantially responsible ie. which

- a) Are properly signed.
- b) Confirm to the terms and conditions and specifications.

6) **Award of Contract**

- a) The purchaser will award the contract to the bidder whose quotations has been determined to be substantially responsive and who has offered the lowest evaluated quotation price.
- b) Not withstanding above, the purchaser reserves the right to accept or refill any quotations and to cancel the bidding process and reject all quotations at any time prior to the award of the contract.

7) The payment will be released after the verification of whole job and the receipt of performa invoice in this office.

8) **Specified conditions**

- (1) OEM/Authorised dealers/Registered Company/Agent are only eligible.
- (2) The payment will be released after verification of whole job.
- (3) The bidder should have authorized service centers/Engineers at Trivandrum for all their quoted equipments.

Sd/-
Assistant Engineer (Ele)
Kerala State Co-operative Bank Ltd.

Format of Quotation for UPS sets/Scrap

Sl. No.	Model No./ Description of goods	Specification	Quantity	Unit/Quoted Rate	Total

Gross Total cost (Rupees.....)
(in words)

We agree to supply and install the above goods in accordance with the technical specification for a total price of Rs. (amount in figure) (amount in words) within the period specified in the evaluation for quotation.

Name of supplier:

Signature :

Place:

Date:

C5/AE/45/